

ENGLISH VERSION OF THE OFFICIAL FRENCH PROCÈS-VERBAL N° EFR-23-002436-A

Only the original French edition of this procès-verbal is authentic.
Seule l'édition originale en français du présent procès-verbal fait foi.

The French PROCES VERBAL is valid for 5 years starting on June 16, 2023

This report cancels and replaces the English version of the official French procès-verbal n°EFR-23-002436-A

1. DOCUMENT FOLLOW-UP

Review index	Modification	Comment	Date		
0	Creation of the document.	/	June 29 th , 2023	Editor	L. BARBIER
				Auditor	D. FLAMMIER
				Approver	D. FLAMMIER
1	Correction of the composition	/	July 05 th , 2023	Editor	L. BARBIER
				Auditor	D. FLAMMIER
				Approver	D. FLAMMIER

Applicant

MERMET SAS
58 chemin du Mont Maurin
38630 VEYRINS
France

Sample reference

SCREEN NATURE

Brief description provided by the applicant

The blind, with in the mass fire-retardant, is made of 90% glass fabric and 10% fire-retardant impregnation.

Mass per unit area determined by the laboratory

165 g/m² ± 10%

Thickness measured by the laboratory

0.19 mm ± 10%

Colour

All colors

End-use condition

Sun protection blinds for indoor use

Standard of tests:

- **NF P 92-507 (2004)** - Building - Interior fitting materials - Classification according to their reaction to fire
- **NF P 92-503 (1995)** - Reaction to fire tests - Electrical burner test used for flexible materials

Classification obtained in the official Procès Verbal:

M1

Valid for any application for which the product is not subjected to the CE marking.

Durability of the classification (NFP 92-512: 1986): Supposedly unlimited

Taking into account the criteria resulting from the tests described in the test report n°EFR-23-002436-BE – Révision 1 from July 05th, 2023.

This test report only demonstrates the characteristics of the test sample and does not prejudice the characteristics of similar products. It does not provide a certification of products within the Article L.115-27 of the Consumer Code and the Law of June 3rd, 1994. Efectis France is approved for fire reaction tests according to the Decree of December 29th, 2016 amending the Decree of February 5th, 1959.

Les Avenières Veyrins-Thuellin, on July 05th, 2023